

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No:

269. / W-47 / 14.

Date: 05/04/2024.

It is certified that an inspection team headed by Er. Surendra Pratap Singh, Assistant Engineer, Division Office, U.P. Jal Nigam (Rural), Lucknow inspected the Holy Public School, Add : School plot sector 12, Near R.G, Euphoria Vrindavan Yojna, Lucknow on 03.04.2024 and on the basis of water test report (Attached) bearing no UPJN/LKO/13 dated 04.04.2024 of District level Water Analysis Laboratory (PHED Lab) certified that the Holy Public School, Lucknow has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 year

Signature with Seal :



Name

: Er. Manoj Kumar Maurya

Designation


: Executive Engineer

To,

Holy Public School,  
Add : School plot sector 12, Near R.G,  
Euphoria Vrindavan Yojna, Lucknow

  
PRINCIPAL  
HOLY PUBLIC SCHOOL  
Kahlon, Sector-12, Vrindavan Yojna  
Lucknow-UP-226029

MANAGER  
HOLY PUBLIC SCHOOL  
Kahlon, Sector-12, Vrindavan Yojna  
Lucknow-UP-226029





**DISTRICT LEVEL WATER ANALYSIS LABORATORY,  
U.P JAL NIGAM, (RURAL), LUCKNOW**



Format NO.7.5 F-01

Test Report		
Report No	UPJN/LKO/13	Page no.1
customer details		
Office Name and Address	HOLY PUBLIC SCHOOL	
Ref Letter NO. & Date		
Basic details of Sample (Drinking Water)		
Sample description	ACID / NON ACIDIC BOTH	
District	LUCKNOW	
Gram panchayat		
Habitat	SECTOR -12 NEAR R.G. EUPHORIA VIRINDAVAN YOJNA, LUCKNOW	
water source	Tap water	
Quantity of sample	2000 ml	
Receiving Date	03-04-2024	
Sample Depositor	Sampling Method	IS:17614
Analysis Start date : 03-04-2024	Analysis completion Date	04-04-2024

Technical Data of Analysis					
S.No.	Analysed parameters	Observed Value	Specified Values as per		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	2	3	4	5	6
1	*pH @25°C	7.13	6.5-8.5	6.5-8.5	IS 3025 (part 11)
2	*Turbidity(NTU)	0.002	1	5	IS 3025 (part 10)
3	*TDS (mg/l)	72.57	500	2000	IS 3025 (part 16)
4	*Chloride (mg/l)	14	250	1000	IS 3025 (part 32)
5	*Total Alkalinity (mg/l)	48	200	600	IS 3025 (part 23)
6	*Total Hardness(mg/l)	104	200	600	IS 3025 (part 21)
7	*Fluoride (mg/l)	0.381	1	1.5	APHA -24th edition
8	*Nitrate (mg/l)	0.19	45	45	APHA -24th edition
9	*Sulphate(mg/l)	1.01	200	600	APHA-24th edition
10	*Iron(mg/l)	0	0.3	No relaxation	APHA-24th edition
11	Arsenic(mg/l)	0	0.01	0.05	APHA-24th edition
12	Conductivity (ms)	120	No relaxation		APHA-24th edition
14	*Colour(cu)	1	5	15	APHA-24th edition
15	Total coliform	0	No relaxation		APHA-24th edition
16	E. coli	0	No relaxation		APHA-24th edition
17	free residual chlorine	0.2	0.2	1	APHA-24th edition

- Note
1. This certificate refers only to the particular sample (s) submitted for testing.
  - 2.\* Symbol shows NABL accreditation status of parameter.
  3. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from head laboratory.
  4. The test result reported in this certificate are valid at time of and under the stated conditions of measurements.
  5. Sample will be stored up to 15 days (in case of perishable items only) from the date of issue.

Report Prepared by

**PRINCIPAL**  
**HOLY PUBLIC SCHOOL**  
 Kalyon, Sector-12, Vrindavan Yojna  
 Lucknow-UP-226029

**MANAGER**  
**HOLY PUBLIC SCHOOL**  
 Kalyon, Sector-12, Vrindavan Yojna  
 Lucknow-UP-226029

Authorised Signatory  
 U.P. Jal Nigam (Rural)